

# REGISTER OF CONDITIONS

No. 62 A 169  
SRA 158

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951  
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)  
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

Cat. No. R.S.12 Book 3 Part 17, Fifth Edn. E.C.A.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
14th September 1966	North West Sussex Water Board Hurst Road, Horsesham, Sussex.	Five new outlets and the new discharges therefrom.
<p>USE OF NEW OR ALTERED OUTLET</p> <p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) PRECISE LOCATION OF OUTLET Hardham Pumping Station and Treatment Works, Pulborough A) TQ03311782 B) TQ03291781 C) TQ03271780</p> <p>(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) The outlets shall be constructed and sited to the satisfaction of the Chief Technical Officer of the Authority.</p> <p>(iii) USE OF OUTLET</p> <p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>	<p>DISCHARGE OF TRADE OR SEWAGE EFFLUENT</p> <p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) NATURE AND COMPOSITION OF DISCHARGE (a) the pH of each discharge shall not exceed 9. (b) The solids-in-suspension in each discharge shall not exceed 60 parts per million</p> <p>(ii) TEMPERATURE OF DISCHARGE</p> <p>(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES</p> <p>* (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES</p>	<p>REMARKS-</p> <p>(v) DATE OF EXPIRATION OF PERIOD SPECIFIED The terms of this Consent will not UNDER S-5(2) OF 1961 ACT without the consent in writing of the person to whom this Consent is given (or his successor) be altered before the expiration of the period ending with the 14th September 1968.</p>

TQ0317  
~~1001~~